

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7167-0656:109

Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: RadioShack, 100 Throckmorton St., Ste 1300, Ft. Worth TX 76102-2802
Contact: Linda Dickerson * (817) 415-2797 Fax (817) 415-3092*

DESIGN: Model SAFEHOUSE 49-485 residential fire alarm control unit. Power-limited. Refer to listee's data sheet for detailed product description and operational considerations. Basic components:

49-485	Control Unit
49-484	Remote Command Console
ELM	End-of-line Module

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/part number and UL label.

APPROVAL: Listed as a household control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7167-1377:101

*Rev. 06-15-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager